



NOTE: PRESURE TANK SET BY DESIGN OF SYSTEM 2 PSI BELOW CUT IN PRESSURE BY CONTRACTOR.

# RMS

RAINWATER MANAGEMENT SOLUTIONS

## 300 W CORGAL W/ DAY TANK SCHEMATIC

ALL GRADES & ELEVATIONS TO BE SITE  
VERIFIED PRIOR TO CONSTRUCTION

DRAWN BY: JH 2/23/2026  
CHECKED BY: ME 2/23/2026

REV 0

NOT TO SCALE

DRAWING FOR ILLUSTRATIVE PURPOSES ONLY. NOT FOR CONSTRUCTION.  
DIMENSIONS AND LAYOUT SUBJECT TO CHANGE

RAINWATER MANAGEMENT SOLUTIONS, 1-866-653-8337  
WWW.RAINWATERMANAGEMENT.COM

D00W